This declaration of conformity is issued under the sole responsibility of the manufacturer:

| | |
|---|---|
| **Company** | HARDWARIO a.s. (Czech company registration number: 04998511) |
| **Registered office** | U Jezu 525/4, 460 01 Liberec, Czech Republic |

The company is registered in the Commercial Register maintained by the Regional Court in Ústí nad Labem, B 2864.

**Object of the declaration:**

| | |
|---|---|
| **Product name** | CHESTER Control |
| **Product description** | A remote monitoring and control unit for industrial automation. It provides four configurable analog or digital inputs (0–28 V voltage, 4–20 mA current loop, NPN/PNP) and four switched outputs, controlled remotely over cellular LTE-M/NB-IoT or LoRaWAN networks. The device operates from −30 to +70 °C in an IP67-rated enclosure. |
| **Power supply** | External DC 6 V to 28 V power supply |
| **Radio communication** | Cellular LTE-M or NB-IoT, LoRaWAN, Bluetooth Low Energy (2.4 GHz) |

**The object of the declaration described above is in conformity with the relevant Union harmonisation legislation:**

- Directive 2011/65/EU: Restriction of Hazardous Substances (RoHS)
- Directive 2014/53/EU: Radio Equipment Directive (RED)

**This product is compliant with the following standards:**

- Standard EN 18031-1:2024
- Standard EN IEC 60529:1991 + A1:2000 + A2:2013
- Standard EN IEC 61010-1:2010 + A1:2019
- Standard EN IEC 62311:2020
- Standard EN IEC 63000:2018
- Standard ETSI EN 300 220-2 V3.2.1
- Standard ETSI EN 300 328 V2.2.2
- Standard ETSI EN 301 489-1 V2.2.3:2019
- Standard ETSI EN 301 489-3 V2.3.2
- Standard ETSI EN 301 489-17 V3.2.4
- Standard ETSI EN 301 489-52 V1.3.1:2024
- Standard ETSI EN 301 908-1 V15.2.1
- Standard ETSI EN 301 908-13 V13.2.1

| | |
|---|---|
| **Date and place** | November 1, 2026, Liberec (Czech Republic) |
| **Name and position** | Pavel Hübner, CEO |
| **Signature** |  |

Technical documentation is retained at the company's registered address.