This declaration of conformity is issued under the sole responsibility of the manufacturer:

Company	HARDWARIO a.s. (Czech company registration number: 04998511)
Registered office	U Jezu 525/4, 460 01 Liberec, Czech Republic

The company is registered in the Commercial Register maintained by the Regional Court in Ústí nad Labem, B 2864.

Object of the declaration:

Product name	CHESTER Display
Product description	A monitoring unit with a 400 × 240 px graphical LCD and an integrated buzzer for on-site data readout and alarm signalling. It measures temperature and humidity on multiple channels and transmits the data over cellular LTE-M/NB-IoT or LoRaWAN networks. The device operates from −20 to +70 °C in an IP65-rated enclosure.
Power supply	Primary lithium battery pack (3.6 V nominal, 7 700 mAh) or external DC power supply
Radio communication	Cellular LTE-M or NB-IoT, LoRaWAN, Bluetooth Low Energy (2.4 GHz)

The object of the declaration described above is in conformity with the relevant statutory requirements.

This product complies with the essential requirements of the following UK regulations:

- Radio Equipment Regulations 2017
- Restriction of the Use of Certain Hazardous Substances in Electrical and Electronic Equipment Regulations 2012

Applied designated standards:

- Standard EN 18031-1:2024
- Standard EN IEC 60529:1991 + A1:2000 + A2:2013
- Standard EN IEC 61010-1:2010 + A1:2019
- Standard EN IEC 62311:2020
- Standard EN IEC 63000:2018
- Standard ETSI EN 300 220-2 V3.2.1
- Standard ETSI EN 300 328 V2.2.2
- Standard ETSI EN 301 489-1 V2.2.3:2019
- Standard ETSI EN 301 489-3 V2.3.2
- Standard ETSI EN 301 489-17 V3.2.4
- Standard ETSI EN 301 489-52 V1.3.1:2024
- Standard ETSI EN 301 908-1 V15.2.1
- Standard ETSI EN 301 908-13 V13.2.1

Date and place	November 1, 2026, Liberec (Czech Republic)
Name and position	Pavel Hübner, CEO
Signature	

Technical documentation is retained at the company's registered address.